

2430 "E" Street, N. W.
Washington, D. C.
22 March 1954

25X1A9a



25X1A

Subject: Contract [REDACTED]
Road Work

25X1A9a

Dear [REDACTED]

25X1A9a

Reference is made to your letters addressed to [REDACTED] dated 10 February and 16 March 1954, relative to the change in specification for the sub-grade paving as proposed in [REDACTED] letter to you, dated 9 February 1954, subject Paving.

25X1A5a1

25X1A

In accordance with your recommendation, "Section 1 - General", in [REDACTED] proposal is rejected since the items herein are fully covered in the contract specifications. "Section 2 - Sub-grade", "Section 3 - Base Material", and "Section 4 - Pavement" are approved as a minor modification to the contract, with the following exception: Section 3(a) second paragraph, should be changed to read, "Rock base material shall be placed in an amount to obtain a minimum depth of eight inches (8") after compaction ...".

Inasmuch as the work involved will not change the contract price or extend completion date, a proposed modification request or change order is not considered necessary.

Very truly yours,



Contracting Officer

25X1A9a